

Form DE – 2

(See rule 113 of the Explosives Rules, 2008)

(Distance Form to be attached to the licence)

Safety distances required to be kept clear around magazine for high explosives or fire works or factory licence number.....in formgranted to.....

Type of structure(s)	Safety distance meters	
Inside Safety Distance (ISD)		
1. Room or works used in connection with the magazine		
2. Any other explosives magazine.		
3. Magazine office for this magazine		
Middle Safety Distance (MSD)		
4. Dwelling house of the security guard of the magazine		
5. Railway including private Railway		
6. Canal (in active use) or other navigable water		
7. Dock or Pier or Jetty		
8. Public highway or Public roads		
9. Private road which is a principal means of access to a temple, mosque, church, gurudwara or other places of worships, hospital, college, school or factory		
10. River embankment or sea embankment or Public well		
11. Reservoir or bounded tank or rope way		
12. Wind mill or solar panel for power generation		
Outside Safety Distance(OSD)		
13. Dwelling house		
14. Govt. & Public building		
15. Temple, mosque, gurudwara, church or other place of worship		
16. Shops, market place, public, recreation and sports ground, College, School, hospital, theatre, cinema or other buildings, where the public are accustomed to assemble		
17. Factory		
18. Buildings or works used for the storage in bulk of petroleum spirit, gas or other inflammable or hazardous substance		
19. Building or works used for the manufacture of explosives or of articles which contain explosives		
20. Aerodrome		
21. Furnace, Kiln or chimney		
22. Quarry or mine pit head		
23. Power house or electric sub-station		
24. Wireless Station		
25. Warehouse or other storage buildings		
26. Any other protected works		
Over head Electric lines		
27. Elec. Power over head Transmission lines above 440 V		
27. Elec. Power over head Transmission lines up to 440 V		

[Controller of Explosives/Chief Controller of Explosives]